

OSM/LUM DECISION SHEET (DSH)

Standard(s) (incl. year)	Subclause(s):	Tracking No.	Year
EN 60598-1:2015/A1:2018	5.2.10 – 5.3.5	DSH 0883A	2019
Category:			
LITE			
Subject:	Key words:	Developed by	Approved at
Cord anchorage on lampholder	<ul style="list-style-type: none"> - Class I – II - III - Live parts - Lampholder 	OSM/LUM-ETF5	2019 ETICS Plenary Meeting
Question			
<p>Is cord anchorage on lampholders used as connectors necessary where the cable may be subjected to strain during lamp replacement (e.g. GU 10 and GZ 10)?</p>			
Decision			
<p>The following conditions apply:</p> <ul style="list-style-type: none"> - class III welded or crimped lampholder contacts are accepted without cord anchorage provided that they are tested according to lampholder standard; - class III, screw or screwless terminals - cord anchorage is required; - 230 V, class I or class II not acceptable; (cord anchorage, sleeve, protection against contact with live parts, etc.,... is required). 			
Explanatory notes			
